International Journal of
AI ELECTRICAL CIVIL AND MECHANICAL ENGINEERING
Peer Reviewed, Referred & Indexed Journal
ISSN: 3070-0434 www.zesterapublications.com Original Research Paper

DIGITAL TWIN-BASED CONDITION MONITORING AND PREDICTIVE MAINTENANCE OF POWER SYSTEM ASSETS

[1]Dr.L.Kishore,[2]Mr.CH.Krishna Prasad,[3]Mogarapu Anil Kumar

[1]Ph.D., Associate Professor& IQAC Coordinator, Department of Electrical and Electronics Engineering, Srichaitanya institute of Technology&Research, Khammam-507210

[1]Email: kishorephd724@gmail.com

[2]Head of the Department, Department of Electrical and Electronics Engineering, Srichaitanya Institute of Technology&Research,Khammam-507210

[2]Email: scitkmm.eeehod@gmail.com

[3]Assistant professor, Department of Electrical and Electronics Engineering, Sri chaitanya institute of technology and research,Khammam-Hyderabad Road, Ponnekal (V), Khammam Rural, Khammam, Telangana - 507170

[3]Email: mogarapuanil@gmail.com

ABSTRACT

The increasing complexity of modern power systems has created a strong need for reliable condition monitoring and timely maintenance of critical power system assets such as transformers, generators, circuit breakers, and transmission equipment. Traditional maintenance approaches mainly depend on fixed schedules or manual inspections, which may result in unnecessary maintenance, unexpected failures, and increased operational costs. This paper proposes a Digital Twin-Based Condition Monitoring and Predictive Maintenance framework for power system assets. The proposed system creates a virtual representation of physical assets by continuously collecting real-time operational data such as temperature, voltage, current, vibration, load, and other relevant health parameters. These data are processed and analyzed using machine learning techniques to identify abnormal operating conditions, estimate asset health, and predict potential failures before they occur. The Digital Twin continuously synchronizes with the physical asset, enabling real-time visualization of its operating condition and historical performance. Predictive models analyze degradation patterns and generate early warnings when abnormal behavior or failure risks are detected. The framework supports condition-based maintenance by helping operators determine the appropriate time for inspection, servicing, or component replacement. By combining real-time monitoring, digital modeling, data analytics, and predictive maintenance, the proposed approach can reduce unplanned outages, improve asset reliability, increase equipment lifetime, and optimize maintenance costs. The system provides a scalable and intelligent solution for developing more reliable, efficient, and resilient smart power grids.

Keywords: Digital Twin, Condition Monitoring, Predictive Maintenance, Power System Assets, Machine Learning, Asset Health Monitoring, Fault Detection, Failure Prediction, Smart Grid, Real-Time Monitoring, Equipment Reliability, Data Analytics, Preventive Maintenance, Power Transformers, Intelligent Maintenance.

I.INTRODUCTION

Power systems consist of several critical assets such as power transformers, generators, circuit breakers, transmission lines, cables, and switchgear. The reliable operation of these assets is essential for maintaining a continuous and stable electricity supply. As power networks become larger and more complex, unexpected equipment failures can lead to power interruptions, increased maintenance costs, equipment damage, and reduced system reliability. Therefore, effective monitoring and maintenance of power system assets have become important

International Journal of
AI ELECTRICAL CIVIL AND MECHANICAL ENGINEERING
Peer Reviewed, Referred & Indexed Journal
ISSN: 3070-0434 www.zesterapublications.com Original Research Paper

requirements in modern electrical power networks.

Conventional maintenance methods are generally based on scheduled inspections, periodic servicing, and corrective maintenance after a fault occurs. Although these approaches can help maintain equipment performance, they may not accurately represent the actual health condition of an asset. Some equipment may be serviced even when it is operating normally, while hidden faults may remain undetected between scheduled inspections. Condition-based and predictive maintenance approaches provide a better solution by using operational data to determine the actual condition of equipment and identify possible failures at an early stage.

Digital Twin technology has emerged as an effective approach for intelligent asset monitoring. A Digital Twin is a virtual representation of a physical system or equipment that is continuously updated using data obtained from the corresponding physical asset. In power systems, sensors and monitoring devices can collect parameters such as voltage, current, temperature, vibration, load, pressure, insulation condition, and operating status. These measurements can be transferred to the Digital Twin to provide an updated representation of the asset's behavior and health condition.

The integration of Digital Twin technology with data analytics and machine learning further improves predictive maintenance capabilities. Historical and real-time data can be analyzed to recognize abnormal patterns, detect developing faults, estimate equipment degradation, and predict possible failures. Based on these predictions, maintenance activities can be planned before a serious fault occurs. This reduces unnecessary maintenance operations while minimizing the possibility of unexpected equipment shutdowns.

This work focuses on developing a Digital Twin-Based Condition Monitoring and Predictive Maintenance framework for Power System Assets. The proposed approach combines real-time data acquisition, virtual asset modeling, condition assessment, fault detection, and predictive analysis within a unified framework. The system aims to provide early warnings regarding asset deterioration and support maintenance decision-making. Through continuous monitoring and intelligent prediction, the proposed framework can improve equipment reliability, extend asset lifetime, reduce maintenance costs, and contribute to the safe and efficient operation of modern power systems.

II.LITERATURE SURVEY

Moghadam et al. (2021): Hooman Mohammadi Moghadam, Hossein Foroozan, Meysam Gheisarnejad, and Mohammad-Hassan Khooban reviewed emerging applications of Digital Twin technology in power systems. Their study explained how virtual models can represent the characteristics and behavior of physical power-system components. The authors discussed applications involving wind turbines, solar panels, power electronic converters, and shipboard electrical systems. The study highlighted that supervisory Digital Twin systems can support failure reduction and cost-effective operation. This work established the importance of integrating Digital Twins with AI, IoT, and big-data technologies for modern power-system applications.

Barricelli et al. (2020): Barricelli and co-authors investigated the use of Digital Twins for maintenance through a comprehensive literature review. The study examined how Digital Twins can support maintenance activities across different industrial sectors, including energy-related applications. The authors emphasized that Digital Twins can improve maintenance

International Journal of
AI ELECTRICAL CIVIL AND MECHANICAL ENGINEERING
Peer Reviewed, Referred & Indexed Journal
ISSN: 3070-0434 www.zesterapublications.com Original Research Paper

decision-making by providing a continuously updated representation of physical assets. Their work also identified research gaps related to implementation strategies and the integration of Digital Twins with intelligent maintenance techniques.

Fuller et al. (2021): The authors examined Digital Twins and their integration into electric power systems. Their work described Digital Twins as an important technology for grid modernization and highlighted their ability to improve the understanding of power-system behavior. The study emphasized the use of real-time information to simulate operating conditions and predict possible system scenarios. The authors concluded that Digital Twin technology can contribute to improved efficiency, reliability, and functionality of electric power systems.

Liu et al. (2022): He Liu, Min Xia, Darren Williams, Jianzhong Sun, and Hongsheng Yan presented a systematic literature review on Digital Twin-driven condition monitoring. The researchers analyzed how Digital Twins can provide data support, enhance monitoring capabilities, and enable a shift from traditional maintenance toward intelligent maintenance. The study discussed different Digital Twin modeling approaches and their integration with monitoring algorithms. It also identified challenges related to data management, high-fidelity modeling, behavior characterization, standardization, and uncertainty quantification.

Kim et al. (2022): Wongon Kim, Sunuwe Kim, Jingyo Jeong, Hyunjae Kim, Hyeonchan Lee, and Byeng D. Youn proposed a Digital Twin approach for on-load tap changers used in power transformers. The study used data-driven dynamic model updating and optimization-based operating-condition estimation. The authors focused on vibration signals because they can provide useful information about the mechanical state and faulty operating conditions of tap changers. Their work demonstrated how Digital Twin models can combine physical knowledge and observed operational data for asset health estimation.

Fang and Zhu (2022): Fang and Zhu investigated Digital Twin technology for prognostics and health management of power transformers. The authors explained that transformer PHM is important for moving from conventional periodic maintenance toward condition-based and predictive maintenance. Their proposed framework considered the integration of transformer operating parameters, multi-physical and multi-scale modeling, and fault analysis within the virtual environment. The study identified Digital Twin technology as an important direction for improving transformer monitoring and maintenance and discussed its key technologies, challenges, and future development.

Moghadam et al. (2022): A systematic study of predictive maintenance using Digital Twins analyzed 42 primary research studies. The authors found that Digital Twins can provide real-time representations of physical machines and generate useful degradation information for predictive-maintenance algorithms. The study examined Digital Twin platforms, modeling approaches, communication protocols, application domains, and design patterns. It also identified computational burden, data diversity, and model and asset complexity as important challenges in developing Digital Twin-based predictive-maintenance systems.

Zhong et al. (2023): Dong Zhong, Zhelei Xia, Yian Zhu, and Junhua Duan presented an overview of predictive maintenance based on Digital Twin technology. The authors discussed the limitations of traditional predictive-maintenance approaches and examined how Digital Twins can improve equipment monitoring and maintenance decisions. Their study

International Journal of
AI ELECTRICAL CIVIL AND MECHANICAL ENGINEERING
Peer Reviewed, Referred & Indexed Journal
ISSN: 3070-0434 www.zesterapublications.com Original Research Paper

highlighted the integration of Digital Twins with data analytics and intelligent algorithms to improve failure prediction and maintenance planning. The research provides a general foundation for developing intelligent predictive-maintenance frameworks.

Mansour et al. (2023): Mansour and co-authors presented a comprehensive survey of IoT and Digital Twin applications in electrical power systems. The study specifically examined condition monitoring and diagnosis of power transformers, electrical grids, and substations. The authors described how IoT sensors can provide real-time operational data while Digital Twins can use these data to represent and analyze the behavior of physical power-system assets. The work also discussed implementation challenges and future opportunities for combining IoT and Digital Twin technologies in electrical power systems.

III.EXISTING SYSTEM

The existing maintenance practices for power system assets are primarily based on preventive maintenance, corrective maintenance, and periodic condition monitoring. In preventive maintenance, equipment such as transformers, generators, circuit breakers, and transmission components are inspected and serviced at predefined time intervals. These schedules are generally prepared according to equipment age, operating hours, manufacturer recommendations, and previous maintenance records. Although this approach helps reduce some failures, maintenance may be performed even when an asset is operating normally, resulting in unnecessary labor, equipment downtime, and maintenance expenses.

Another commonly used approach is condition-based monitoring, where sensors and diagnostic instruments are used to measure important operating parameters. Parameters such as transformer temperature, oil condition, voltage, current, vibration, load, pressure, and insulation characteristics are periodically or continuously monitored. When a parameter exceeds a predefined threshold, an alarm is generated for further inspection. However, conventional monitoring systems often depend on fixed threshold values and may not effectively identify gradual degradation or complex relationships between multiple operating parameters.

Traditional fault detection and diagnostic systems are also used to identify abnormal operating conditions in power equipment. These systems typically analyze sensor measurements, electrical signals, or inspection results to determine whether a fault has occurred. While they can provide useful information after an abnormal condition appears, they may have limited capability to predict failures sufficiently in advance. Consequently, unexpected equipment failures can still occur, leading to unplanned outages, costly repairs, and reduced power-system reliability.

In many existing systems, monitoring data are collected and stored separately from simulation or maintenance-management platforms. There is often no continuously synchronized virtual representation of the physical asset. This makes it difficult for operators to visualize the current health condition of equipment, compare present behavior with historical behavior, and evaluate possible future operating conditions. The lack of integration between real-time monitoring, equipment modeling, and predictive analytics is therefore a major limitation.

Furthermore, existing maintenance systems commonly focus on individual equipment parameters or individual assets rather than providing an integrated view of asset health. Machine-learning methods are increasingly being applied for fault classification and failure prediction, but their effectiveness depends heavily on the availability and

International Journal of
AI ELECTRICAL CIVIL AND MECHANICAL ENGINEERING
Peer Reviewed, Referred & Indexed Journal
ISSN: 3070-0434 www.zesterapublications.com Original Research Paper

quality of historical data. Conventional approaches may also provide predictions without sufficient visualization or interpretation of the physical asset's current state.

Overall, the existing system provides basic monitoring and maintenance capabilities but has limitations in real-time asset representation, early failure prediction, continuous health assessment, data integration, and intelligent maintenance scheduling. These limitations create a need for a more advanced approach that combines real-time sensor information, virtual asset modeling, data analytics, and machine learning. The proposed Digital Twin-based system addresses these limitations by maintaining a dynamic virtual representation of power-system assets and using predictive analysis to identify potential failures before they develop into critical problems.

IV.PROPOSED SYSTEM

The proposed system introduces a Digital Twin-Based Condition Monitoring and Predictive Maintenance framework for monitoring the health and performance of critical power system assets. The main objective is to create a virtual representation, or Digital Twin, of physical equipment such as power transformers, generators, circuit breakers, and transmission equipment. The Digital Twin continuously reflects the operating condition of the corresponding physical asset using real-time and historical data. This provides operators with a better understanding of equipment behavior and helps identify abnormal conditions at an early stage.

The proposed framework begins with real-time data acquisition from sensors installed on the physical power system assets. Important parameters such as voltage, current, temperature, vibration, load, pressure, frequency, and other equipment-specific measurements are collected continuously. The collected data are transmitted to the monitoring platform through suitable communication technologies. Before analysis, the data are cleaned, normalized, and processed to remove noise, missing values, and inconsistent measurements. This improves the reliability of subsequent condition assessment and prediction.

A Digital Twin model is then developed for each monitored asset. The virtual model represents the physical equipment and its operational characteristics. Real-time sensor measurements are synchronized with the Digital Twin so that the virtual asset reflects the current state of the physical equipment. Historical operating data can also be incorporated to study degradation patterns and changes in equipment performance over time. This continuous synchronization allows the system to compare normal and abnormal operating behavior more effectively than conventional threshold-based monitoring.

The proposed system incorporates machine-learning-based condition assessment and predictive analytics to identify potential faults and estimate future equipment health. The trained models analyze multiple parameters simultaneously and detect patterns associated with equipment degradation or failure. Depending on the asset and available data, classification algorithms can be used for fault identification, while regression or time-series models can estimate health indicators and remaining useful life. When the predicted condition indicates an increased risk of failure, the system generates an early warning for the operator.

A major feature of the proposed system is predictive maintenance planning. Instead of waiting for equipment failure or performing maintenance at fixed intervals, maintenance activities can be scheduled according to the predicted health condition of the asset. The system can categorize equipment into different health states, such as normal,

International Journal of
AI ELECTRICAL CIVIL AND MECHANICAL ENGINEERING
Peer Reviewed, Referred & Indexed Journal
ISSN: 3070-0434 www.zesterapublications.com Original Research Paper

warning, degraded, and critical. This enables maintenance teams to prioritize critical assets, plan inspections in advance, and replace or repair components before severe failures occur.

The framework also provides a centralized monitoring dashboard through which operators can view real-time equipment parameters, Digital Twin status, health indicators, detected faults, prediction results, and maintenance alerts. Historical trends can be visualized to understand how the condition of an asset changes over time. The combination of real-time monitoring and predictive information helps operators make faster and more informed maintenance decisions.

Overall, the proposed Digital Twin-based system aims to overcome the limitations of conventional maintenance approaches by integrating real-time monitoring, virtual asset modeling, machine learning, fault detection, health assessment, and predictive maintenance into a unified framework. The approach can reduce unexpected equipment failures and unplanned outages while improving asset reliability, equipment lifetime, maintenance efficiency, and overall power-system availability.

V.SYSTEM ARCHITECTURE

The proposed architecture begins with the physical layer, which contains important power system assets such as transformers, generators, circuit breakers, and transmission lines. These assets are continuously exposed to different electrical and mechanical operating conditions. Sensors are installed on these assets to collect important parameters such as temperature, vibration, voltage, current, oil pressure, load, and frequency. The collected information provides a clear indication of the current operating condition and helps identify early signs of equipment degradation.

The sensor data are transferred through the communication layer, where an IoT gateway collects and forwards the information to the central monitoring platform. Communication technologies such as Wi-Fi, 5G, or Ethernet can be used for reliable data transmission. The gateway acts as an interface between the physical equipment and the software-based monitoring system, allowing real-time equipment information to reach the data-processing environment.

The data management layer receives both real-time and historical equipment data. The collected information is stored and processed before being used for further analysis. Data preprocessing operations such as cleaning, normalization, and feature extraction are performed to remove incorrect or unnecessary information and prepare useful features for the prediction models. Historical data are also maintained so that the system can analyze previous equipment behavior and identify degradation patterns.

The Digital Twin and analytics layer represents the main intelligence of the proposed architecture. A virtual Digital Twin of the physical power system asset is created and continuously synchronized with the actual equipment using real-time sensor information. Machine-learning techniques analyze the synchronized data to perform condition assessment, fault detection, and failure prediction. The system can also estimate the health condition and Remaining Useful Life (RUL) of the asset, allowing potential failures to be identified before they result in serious equipment damage or unexpected outages.

The results obtained from the Digital Twin and machine-learning models are transferred to the maintenance decision layer. When abnormal behavior or a high risk of failure is detected, the system generates early warnings and alerts. Based on the predicted health condition, maintenance activities can be planned according to the actual condition of the equipment. This helps maintenance teams determine which assets require

International Journal of
AI ELECTRICAL CIVIL AND MECHANICAL ENGINEERING
Peer Reviewed, Referred & Indexed Journal
ISSN: 3070-0434 www.zesterapublications.com Original Research Paper

immediate inspection, repair, or replacement and supports better scheduling and resource allocation.

The visualization layer provides a user-friendly interface for operators and maintenance personnel. The dashboard displays real-time equipment parameters, asset health status, Digital Twin information, prediction results, maintenance alerts, and historical trends. By presenting the information in an understandable form, the dashboard enables operators to quickly identify abnormal assets and take appropriate maintenance actions.

Finally, the architecture includes a feedback mechanism for continuous improvement. Information obtained after inspection, repair, or replacement can be fed back into the system along with newly collected operational data. This information can be used to improve the Digital Twin and machine-learning models over time. Therefore, the complete architecture creates a continuous cycle of data collection, monitoring, analysis, prediction, maintenance, and feedback, helping improve the reliability, availability, and operational efficiency of power system assets.




Fig 5.1 System Architecture

VI.IMPLEMENTATION



Fig 6.1 Login Page



Fig 6.2 Dashboard Page




Fig 6.3 Real-time Monitoring Page




Fig 6.4 Predictive Maintanance Page

VII.CONCLUSION

The proposed Digital Twin-Based Condition Monitoring and Predictive Maintenance system provides an intelligent approach for improving the reliability and operational efficiency of power system assets. By continuously collecting real-time information from transformers, generators, circuit breakers, and transmission

International Journal of
AI ELECTRICAL CIVIL AND MECHANICAL ENGINEERING
Peer Reviewed, Referred & Indexed Journal
ISSN: 3070-0434 www.zesterapublications.com Original Research Paper

equipment, the system can provide a clear view of the current operating condition of each asset. The integration of sensor data with a virtual Digital Twin enables the physical equipment and its digital representation to remain synchronized, making it easier to identify changes in equipment behavior and early signs of degradation.

The use of machine learning and predictive analytics further strengthens the proposed framework by enabling condition assessment, fault detection, failure prediction, and Remaining Useful Life estimation. Instead of depending only on fixed maintenance schedules, the system supports condition-based decisions and allows maintenance activities to be planned before a major failure occurs. The visualization dashboard also provides operators with real-time asset health information, alerts, prediction results, and historical trends, helping them make timely maintenance decisions.

Overall, the proposed framework can help reduce unexpected equipment failures, minimize unplanned power interruptions, optimize maintenance costs, improve asset lifetime, and increase power-system reliability. The combination of Digital Twin technology, IoT-based sensing, data analytics, and machine learning provides a scalable foundation for intelligent maintenance in modern smart grids. Thus, the system represents a practical step toward transforming conventional power-system maintenance into a more proactive, data-driven, and predictive approach.

VIII.FUTURE SCOPE

The future scope of the proposed Digital Twin-Based Condition Monitoring and Predictive Maintenance system is extensive, particularly with the development of smart grids and intelligent power infrastructure. The system can be extended to monitor a larger number of power system assets simultaneously, including transformers, generators, circuit breakers, transmission lines, cables, and renewable-energy equipment. This would allow utilities to create a comprehensive digital representation of an entire power network rather than monitoring individual assets independently.

Future work can focus on integrating advanced artificial intelligence and deep-learning algorithms to improve fault detection and failure prediction accuracy. Models such as LSTM, GRU, CNN, and hybrid deep-learning techniques can be used to analyze complex time-series sensor data and identify subtle degradation patterns. The system can also incorporate explainable AI techniques so that operators can understand why a particular fault or failure prediction has been generated.

The Digital Twin can further be enhanced by incorporating real-time IoT, edge computing, and cloud computing technologies. Edge computing can process critical sensor information closer to the equipment, reducing communication delays and enabling faster fault detection. Cloud platforms can provide large-scale data storage and computational resources for analyzing historical and real-time asset information. This combination can support continuous monitoring of geographically distributed power system assets.

Another important area of future development is Remaining Useful Life (RUL) prediction and automated maintenance scheduling. Future versions of the system can estimate the expected remaining operating time of each asset and automatically prioritize maintenance activities according to failure risk, equipment criticality, available resources, and maintenance cost. This can help utilities optimize maintenance planning and reduce unnecessary equipment shutdowns.

The proposed framework can also be extended to support renewable energy and smart-grid assets, including solar

International Journal of
AI ELECTRICAL CIVIL AND MECHANICAL ENGINEERING
Peer Reviewed, Referred & Indexed Journal
ISSN: 3070-0434 www.zesterapublications.com Original Research Paper

photovoltaic systems, wind turbines, battery energy storage systems, and electric vehicle charging infrastructure. By creating Digital Twins for these components, the system can monitor their health and performance while considering changing environmental and operating conditions.

Finally, future research can focus on developing self-learning and autonomous Digital Twins that continuously update their models using new operational and maintenance data. Cybersecurity mechanisms can also be integrated to protect sensor data, communication networks, Digital Twin models, and maintenance systems from unauthorized access or cyberattacks. These developments can ultimately lead to a more autonomous, secure, accurate, and scalable predictive-maintenance platform capable of supporting the next generation of reliable and intelligent power grids.

IX.REFERENCES

[1]. H. M. Moghadam, H. Foroozan, M. Gheisarnejad, and M.-H. Khooban, "A survey on new trends of digital twin technology for power systems," Journal of Intelligent & Fuzzy Systems, vol. 41, no. 2, 2021. DOI: 10.3233/JIFS-201885.

[2]. Y. Peng, S. Zhao, and H. Wang, "A Digital Twin Based Estimation Method for Health Indicators of DC–DC Converters," IEEE Transactions on Power Electronics, vol. 36, no. 2, pp. 2105–2118, 2021. DOI: 10.1109/TPEL.2020.3009600.

[3]. D. Long, Z. Ye, H. Chen, P. Zhou, et al., "Research on Digital Twin Model and Visualization of Power Transformer," 2021 IEEE International Conference on Networking, Sensing and Control (ICNSC), 2021. DOI: 10.1109/ICNSC52481.2021.9702244.

[4]. Y. Liu, G. Chen, Y. Liu, M. Liping, et al., "Condition Monitoring of Power Electronics Converters Based on Digital Twin," 2021 IEEE 3rd International Conference on Circuits and Systems (ICCS), 2021. DOI: 10.1109/ICCS52645.2021.9697303.

[5]. Y. Jing, X. Wang, Z. Yu, C. Wang, Z. Liu, and Y. Li, "Diagnostic Research for the Failure of Electrical Transformer Winding Based on Digital Twin Technology," IEEJ Transactions on Electrical and Electronic Engineering, vol. 17, pp. 1629–1636, 2022. DOI: 10.1002/tee.23670.

[6]. P. Palensky, M. Cvetkovic, D. Gusain, and A. Joseph, "Digital twins and their use in future power systems," Digital Twin, vol. 1, 2022. DOI: 10.12688/digitaltwin.17435.2.

[7]. J. Liu, J. Sun, H. Yan, and co-authors, "Digital Twin-Driven Machine Condition Monitoring: A Literature Review," Journal of Sensors, 2022. DOI: 10.1155/2022/6129995.

[8]. R. van Dinter, B. Tekinerdogan, and C. Catal, "Predictive maintenance using digital twins: A systematic literature review," Information and Software Technology, vol. 151, 107008, 2022. DOI: 10.1016/j.infsof.2022.107008.

[9]. S. de López Diz, R. Martín López, F. J. Rodríguez Sánchez, E. Díaz Llerena, and E. J. Bueno Peña, "A real-time digital twin approach on three-phase power converters applied to condition monitoring," Applied Energy, vol. 334, 120606, 2023. DOI: 10.1016/j.apenergy.2022.120606.

[10]. M. M. H. Sifat, S. M. Choudhury, S. K. Das, M. H. Ahamed, S. M. Muyeen, M. M. Hasan, M. F. Ali, Z. Tasneem, M. M. Islam, M. R. Islam, M. F. R. Badal, S. H. Abhi, S. K. Sarker, and P. Das, "Towards electric digital twin grid: Technology and framework review," Energy and AI, vol. 11, 100213, 2023. DOI: 10.1016/j.egyai.2022.100213.

[11]. D.-E. A. Mansour, M. Numair, A. S. Zalhaf, R. Ramadan, M. M. F. Darwish, Q. Huang, M. G. Hussien, and O. Abdel-Rahim, "Applications of IoT and digital twin in electrical power systems: A comprehensive survey," IET Generation, Transmission &

Distribution, vol. 17, no. 20, pp. 4457–4479, 2023. DOI: 10.1049/gtd2.12940.

[12]. H. Yao, X. Zhang, Q. Guo, Y. Miao, and S. Guan, "Fault diagnosis method for oil-immersed transformers integrated digital twin model," Scientific Reports, vol. 14, 20355, 2024. DOI: 10.1038/s41598-024-71107-w.

[13]. A. Ma, D. Gao, T. Qin, and W. Wang, "Identification method for inter-turn faults in transformers based on digital twin concept," Frontiers in Energy Research, vol. 12, 1376306, 2024. DOI: 10.3389/fenrg.2024.1376306.

[14]. N. El-Rashidy, Y. A. Sultan, and Z. H. Ali, "Predecting power transformer health index and life expectation based on digital twins and multitask LSTM-GRU model," Scientific Reports, vol. 15, 1359, 2025. DOI: 10.1038/s41598-024-83220-x.

[15]. Q. Li, Y. He, X. Geng, Y. Na, J. Su, X. Liu, B. Deng, Q. Zeng, and K. Zhang, "Digital twin-driven condition monitoring methods for power electronic devices: Application and challenges," Renewable and Sustainable Energy Reviews, vol. 235, 116983, July 2026. DOI: 10.1016/j.rser.2026.116983.

Received: 01-06-2026 | Accepted: 08-07-2026 | Published: 15-07-2026